

	Nursing Home Inspection Report
	Health (Nursing Homes) Act, 1990 and the Nursing Homes (Care and Welfare) Regulations, 1993.
Nursing Home	Kilrush Nursing Home
Number of Residents	12
Registered for	46
Nursing Home Address	Killimer Rd., Kilrush, Co.Clare
Proprietor	Mowlam Healthcare Ltd.
Proprietor's Address (if different from above)	
Person-in-Charge of Nursing Home	Ms. Janet Kiely
Date and Time of Inspection(s)	11/02/2009 1.40pm-4.15pm
Date report issued	19/02/09
Summary of previous report findings	The previous inspection from 12/11/08 showed the nursing home to be substantially compliant with current nursing home inspectorate regulations at the time of inspection.
	Current Inspection Summary Findings
Compliance status	<p>Findings of latest (unannounced) inspection which took place on 11/02/2009</p> <p>The inspectors findings based on the current nursing home inspectorate regulations are as follows:</p>

Inspection Report

Findings

Nursing Home Inspection Report

Health (Nursing Homes) Act, 1990 and the Nursing Homes (Care and Welfare) Regulations, 1993.

Summary Findings of Current Nursing Home Inspection

- Under Care & Staffing the nursing home was compliant with 21 out of 21 regulations.**
 On the basis of this inspection and under current nursing home regulations, the inspection team would consider that the nursing home provides a good standard of Care and Staffing for residents.
- Under Management the nursing home was compliant with 27 out of 27 regulations.**
 On the basis of this inspection and under current nursing home regulations, the inspection team would consider the nursing home to have a good standard of management.
- Under Physical Environment the nursing home was compliant with 10 out of 11 regulations.**
 On the basis of this inspection and under current nursing home regulations, there are issues that need to be addressed as outlined below in relation to the Physical Environment.

Non-Compliance (This section should be deleted if no non-compliances have been recorded)

Based on the most recent nursing home inspection the nursing home is non-compliant under one or more regulations. For more details see below.

Regulation number	14. The registered proprietor and the person in charge of the nursing home shall:—
	(b) make adequate arrangements for the prevention of infection, infestation, toxic conditions, or spread of infection and infestation at the nursing home
Non-Compliance	The sluice room downstairs is still not fully equipped or functional. The sluice room upstairs is in use but does not have a sluice sink connected to the foul drainage. It also should have a liquid soap dispenser for hand washing.
Required Action	The sluice room downstairs to be completed and brought into use. The sluice room upstairs to be completed.
Timescale	Two weeks for the downstairs sluice. The upstairs sluice room to be completed before residents are accommodated upstairs.

Compliance/Non Compliance

All regulations, their reference numbers and the details of those regulations can be viewed in [Nursing Homes \(Care and Welfare\) Regulations, 1993](#).

Comments and Recommendations

	Nursing Home Inspection Report	
<p>Comments and recommendations made by the inspection team as a result of the inspection</p>	<p>Health (Nursing Homes) Act, 1990 and the Nursing Homes (Care and Welfare) Regulations, 1993.</p> <p>Mechanical ventilation should be provided in the smoking room, and also in the cleaning room and store room downstairs. Mechanical ventilation will also be required in the hairdressing room before it comes into use.</p> <p>Towel rails should be fitted in all en-suite bathrooms, particularly those currently in use.</p> <p>A dedicated cleaning room, sufficiently large to store equipment, will be required upstairs once rooms there come into use.</p> <p>On the day of inspection it was noted that the front door handle was loose and appeared broken. It is recommended that it be repaired or replaced.</p>	Recommendations
<p>This report has been issued by</p>	<p>Mr. Fergal Flynn, Local Health Manager</p>	Author